

SIZE 3/4"-2"

## SPRINKLER REQUIREMENTS


## NOTES:

 REDUCED PRESSURE PRINCIPLE ASSEMBLIES (RP) MUST CONFORM TO HCDPU SPECIFICATIONS. REFER TO HCDPU APPROVED LIST OF RP'S.

No. Date By

Revision

- 2. HCDPU APPROVED RP INCLUDES SHUT-OFF VALVES #1 AND #2 AS PART OF THE ASSEMBLY. NO SUBSTITUTIONS SHALL BE PERMITTED.
- 3. TEST COCK #1 SHALL BE UPSTREAM OF SHUT-OFF VALVE #1 AND IS PART OF THE APPROVED ASSEMBLY.
- 4. PIPE MATERIAL AND FITTINGS SHALL BE AS SPECIFIED IN HCDPU STANDARDS & SPECIFICATIONS.
- 5. INSULATED ENCLOSURE SHALL BE AS SPECIFIED IN HCDPU ENCLOSURE INFORMATION.
- 6. ALL LOCATIONS FOR RP'S REQUIRE HCDPU APPROVAL.
- 7. NO TAPS, BRANCHES, FH'S OR OTHER ACCESSORIES ARE PERMITTED ON THE PIPING BETWEEN THE RP & METER, EXCEPT FOR REQUIRED CUT OFF VALVE TO BE LOCATED WITHIN 12" OF THE METER BOX.



HARNETT COUNTY
UTILITIES
SYSTEM PROTECTION DIVISION

HARNETT COUNTY, NORTH CAROLINA

| Scales | PLAN | N.T.S. | PROFILE | Hor. | Vert. | As Built | Date | Designed By | Drawn By | Project-Engr | Approved By | Date | Date